

Ideal Fire Solutions

GST NO. 27AABFI9947H1ZZ



Date: - 02nd Jul 2024

FORM "B"

Certified that we Ideal Fire Solutions have carried out the inspection of the Fire Prevention and Life Safety measures installed in **Symbiosis Institute of International Business (SIIB) Hinjewadi Pune.**

We further certify that these installations in the above-mentioned building are maintained in good repair and efficient conditions during this **period 01/01/2024 to 30/06/2024** as required under the provision of Maharashtra Fire Prevention and Life Safety measures Act 2006 (Mah -III of 2007). The details of the inspection of installation carried out by us are mentioned in the report appended herewith.

SHOBHI Digitally signed
by SHOBHIT
T DIKSHIT
Date:
DIKSHIT 2024.07.02
14:15:07 +05'30'

Place: - Pune

Date: - 02/07/2024

Ideal Fire Solutions

Office No. Q-5, Sai Palace,

150A 1 & 2, Paud Road,

Bhusari Colony, Pune - 411038

License No. MFS / LA / RF -91/RD - 86



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-91 / RD- 86

Date: 03.02.2024

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Ideal Fire Solutions** having their registered office at **Office No. Q5, Sai Palace, 150A, 1&2, Paud Rd, Bhusari Colony, Pune 411038** and their contact details are Office Number: 9422319554 and Email ID: ifs0007@gmail.com with PAN registration No. AABFI9947H and GST No. 27AABFI9947H1ZZ to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- 1. Fire Fighting and Sprinkler System: Class C**
- 2. Detection and Fire Suppression System: Class C**

M/s. Ideal Fire Solutions shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **03.02.2024 to 02.02.2026**

Hatyal
Kiran
Asst Director

Digitally signed
by Hatyal Kiran
Date: 2024.02.08
20:39:18 +05'30'

SHOBHIT
DIKSHIT

Digitally signed
by SHOBHIT
DIKSHIT
Date: 2024.02.08
17:59:37 +05'30'

Santosh
Shridhar
Warick

Digitally signed by
Santosh Shridhar
Warick
Date: 2024.02.09
09:53:07 +05'30'

(S S Warick)

Director
Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

LIST / SCHEDULE OF EQUIPMENT INSTALLED

S N	Installed System at Site	UOM	Quantity
A	FIRE HYDRANT SYSTEM -		
1	Riser	1	Nos
a	Hydrants Valves with Required Accessories	2	Nos
b	Canvas Hose with Male Female Coupling	2	Nos
c	Branch Pipe Nozzle	2	Nos
d	Hose Box Single Headed	2	Nos
2	MAIN FIRE PUMP ROOM, TANK AND ACCESSORIES		
a	Booster Pump-3HP	1	Nos
3	Beam Detector in Auditorium	2	Nos
4	PORTABLE FIRE EXTINGUISHER (TOTAL AREA)		
a	ABC Powder type Extinguisher 5 kg	22	Nos
b	Co2 Gas type Extinguisher 4.5 kg	03	Nos

SHOBHI Digitally signed
by SHOBHI
T DIKSHIT
Date:
DIKSHIT 2024.07.02
14:15:30 +05'30'

Thanks & Regards,

For, Ideal Fire Solutions

Shobhit Dikshit

Pune

Date: - 02/07/2024